


# 500 Gallon Top Seam - 1CP with Low Head Pump


**Item #**  
**500T-1CP-LH**

**Top  
View**



**DESIGN NOTES**

- Design per performance test per ASTM C1227
  - Top surface area 23.4 ft<sup>2</sup>
  - f'c @ 28 days; concrete = 6,000 PSI Min.
- Installation:**
- Tank to be set on 5" min. sand bed or pea gravel
  - Tank to be backfilled uniformly on all sides in lifts less than 24" and mechanically compacted
  - Excavated material may be used for backfill, provided large stones are removed
  - Excavation should be dewatered and tank filled with water prior to being put in service for installation with water table less than 2' below grade
  - Meets C1644-06 for resilient connectors
  - Inlet and Outlet identified above pipe
  - Delivered complete with internal piping
  - Control Panel to be mounted in sight line of tank
  - 4' Maximum bury depth



**Section  
View**

ALLOWABLE BURY (Based on Water Table)	
WATER TABLE	ALLOWABLE EARTH FILL
0' - 0"	3' - 0"
1' - 0"	4' - 0"
2' - 0"	4' - 0"
3' - 0"	4' - 0"
DRY	4' - 0"

**Pump:**

- Complete installation (wiring, panel, mounting and start-up procedures)
- Complete warranty

**\*Service contracts available for maintenance.\***

Digging Specs	Invert		Dimensions			Net Capacity	Net Weight		
			Length	Width	Min. Hgt.		Lid	Tank	Total
7' Long x 7' Wide 56" below inlet	Inlet 56"	Outlet 54" or 73"	58"	58"	92"	522 gals	1,340 lbs	4,100 lbs	5,640 lbs



**Phone: 719-395-6764**  
**Fax: 719-395-3727**  
**Website: www.valleyprecast.com**  
**Email: frontdesk@valleyprecast.com**